

**DOWNTOWN IMPROVEMENTS PHASE IIIC
KING STREET – EAST AND WEST SIDE
IFB No. 10304-FY15-23
Addendum #1
May 11, 2015**

1. Questions and Answers:

Question 1: Please clarify the work hours specified for the Downtown Improvements Phase IIIC project. The hours are noted as 7:00 pm to 6:00 am on the front page of the IFB however, on page 34 of 131 under Work Hour restrictions the hours are noted as 9:00 pm to 5:00 am.

Answer 1: The correct work hour restriction is 9:00 p.m. to 6:00 a.m.

Question 2: We would like to request that the Strata Cell be offered as an alternate for the soil cell system (Silva Cell) on this project.

Answer 2: The design standard that was used was the Silva Cell. The contract documents should read “Silva Cell or approved equal”. For any product used on this line item, a full submittal will be required.

END OF ADDENDUM #1